


2000 GALLON TANK
 $1/2" = 1'-0"$



SECTION
 $1/2" = 1'-0"$

NOTE:
 1. PROVIDE MINIMUM 1" CLEAR BETWEEN TOP OF BAFFLE AND UNDERSIDE OF LID.

2000 GALLON HOLDING TANK
 (2000 HT)

Brown Wilbert

WEIGHT=16,800#
 MAX. SOIL COVER= 4'-0"